

Tabela P11.4. Maksimalna trajno dozvoljena strujna opterećenja (u amperima) za PVC izolaciju i dve opterećene žile (temperatura ambijenta: 30⁰C za vazduh i 20⁰C za zemlju)

S (mm ²)	Način polaganja					
	A1	A2	B1	B2	C	D
1	2	3	4	5	6	7
Cu						
1.5	14.5	14	17.5	16.5	19.5	22
2.5	19.5	18.5	24	23	27	29
4	26	25	32	30	36	38
6	34	32	41	38	46	47
10	46	43	57	52	63	63
16	61	57	76	69	85	81
25	80	75	101	90	112	104
35	99	92	125	111	138	125
50	119	110	151	133	168	148
70	151	139	192	168	213	183
95	182	167	232	201	258	216
120	210	192	269	232	299	246
150	240	219	-	-	344	278
185	273	248	-	-	392	312
240	321	291	-	-	461	361
300	367	334	-	-	530	408
Al						
2.5	15	14.5	18.5	17.5	21	22
4	20	19.5	25	24	28	29
6	26	25	32	30	36	36
10	36	33	44	41	49	48
16	48	44	60	54	66	62
25	63	58	79	71	83	80
35	77	71	97	86	103	96
50	93	86	118	104	125	113
70	118	108	150	131	160	140
95	142	130	181	157	195	166
120	164	150	210	181	226	189
150	189	172	-	-	261	213
185	215	195	-	-	298	240
240	252	229	-	-	352	277
300	289	263	-	-	406	313